

REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

To,

Nobility High School
Dholanwal Road, Purhiran, Hoshiarpur

No.: RWTLHSP/2526/00793 Dated : 02/03/2026


Subject: Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 026/NHS/HSP Dated: 26/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 27/02/2026. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Hoshiarpur

To,

D/A: Test Report



**Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur**



REGIONAL WATER TESTING LAB, HOSHIARPUR

Government ITI, Jalandhar Road, Hoshiarpur
rwtlhsp@gmail.com

TEST REPORT

Name & Address of Customer : Nobility High School Dholanwal Road, Purhiraan, Hoshiarpur		Customer Reference No.	No : 026/NHS/HSP Dated : 26/02/2026
		Sample Submitted by	Sucha Singh
		Date of Sample Receipt	27/02/2026
		Analysis Starting Date	27/02/2026
		Analysis completion Date	02/03/2026
Discipline : Chemical Testing, Bacteriological Testing		Group: Water	
ULR No.:		Sample Type :	Water
Test Report No.:	RWTLHSP/2526/00793	Date of Issue :	02/03/2026
Registration no.:	RWTLHSP/REG2526/04957	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Dholanwal Road, Purhiraan, Hoshiarpur / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Hoshiarpur
Latitude:	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.68@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	112.0	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	75.62	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	85.68	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	14.72	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	11.90	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	11.74	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method
12	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
13	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

Continue on next page...

Reviewed and Approved By

Abhishek Joshi

Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur



REGIONAL WATER TESTING LAB, HOSHIARPUR


Government ITI, Jalandhar Road, Hoshiarpur
rwthsp@gmail.com

14	Bacteriological Contamination(B)	ABSENT			--	H2S Vial
----	----------------------------------	--------	--	--	----	----------

This Report is issued under the following terms & Condition :

- 1: The results apply to the sample as received only.
- 2: The sample will be destroyed after retention time unless otherwise specified specially.
- 3: This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- 4: Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
- 5: * Value not available or test not performed for this parameter.
- 6: Temperature condition limit: $25 \pm 5^{\circ}\text{C}$ and Humidity condition limit: $50 \pm 20\%$

Reviewed and Approved By



Abhishek Joshi
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Hoshiarpur

----- End of the Test Report -----